

**ROOF REPLACEMENT  
FOR  
ST. CLAIR CATHOLIC DISTRICT SCHOOL BOARD**

**TENDER  
FOR  
CHRIST THE KING CATHOLIC SCHOOL (612-CP1725)**

**ADDENDUM №**

**1**

The following items shall amend and supersede the Tender Documents which were issued at the Pre-Tender Site Meeting on May 4<sup>th</sup>, 2017.

- 1.** All exterior Wall Ladders must be constructed and installed with a cage around the top section of the ladder.

**END OF ADDENDUM № 1**